

AMENDMENT NO. 1 DECEMBER 2016
TO
IS 10124 (PART 1) : 2009 FABRICATED PVC-U FITTINGS
FOR POTABLE WATER SUPPLIES — SPECIFICATION

PART 1 GENERAL REQUIREMENTS

(Second Revision)

(Page 5, clause A-1.1, line 2) — Substitute ‘4.2’ for ‘4.19’.

(Page 5, clause A-2.1) — Substitute following for the existing clause:

‘**A-2.1** Each test specimen shall consists of a fitting solvent welded to a section of pipe having a minimum length of 250 mm and capable of withstanding minimum internal pressure of 4.2 times working pressure of the fittings for nominal size upto and including 90 and 3.36 times working pressure of the fittings for nominal size above 90. A period of at least 24 h shall be allowed to ensure satisfactory setting of the joint.’